

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		1. CONTRACT ID CODE	PAGE OF PAGES 1   2
2. AMENDMENT/MODIFICATION NO. 000001	3. EFFECTIVE DATE 06/22/2016	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY WAPA (DSW) US DOE/WESTERN AREA POWER DESERT SOUTHWEST REGIONAL OFFICE PO BOX 6457 PHOENIX AZ 85005-6457	CODE DSW	7. ADMINISTERED BY (If other than Item 6)	CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(x) 9A. AMENDMENT OF SOLICITATION NO. DE-SOL-0009877	
		x 9B. DATED (SEE ITEM 11) 06/01/2016	
		10A. MODIFICATION OF CONTRACT/ORDER NO.	
		10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE		

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended.  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not.  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SEE SCHEDULE

Except as provided herein, all terms and conditions of the document referenced in Item 9 A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Eric W. Jordan	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)	16C. DATE SIGNED 06/22/2016

The purpose of this Amendment is to post Contractors' questions and answers, and provide a copy of the Pre-bid Site Visit sign-in sheet.

A. Contractors questions and answers are provided as follows:

Q: Can steel casing be left in holes if necessary?

*A: No. Casing is temporary only.*

Q: Would cold joints just below the anchor bolts at the drilled foundations be acceptable?

*A: No.*

Q: Can we use the property just outside the north end of the APS substation to create a fenced in laydown yard and office trailer location?

*A: Offerors proposing a newly identified laydown yard will need to include the environmental review time in their schedule, per Division 13.B.(7)b.*

Q: Will WAPA be providing survey layout for pole locations?

*A: Refer to the Project Specifications drawings for pole locations.*

Q: Can the dirt spoils generated from the drilled foundations be spread on site or will they need to be hauled off site?

*A: Excavated material can be used as backfill, or be removed off-site. That was how the work is described and analyzed in the Environmental Assessment (DOE/EA-1948, Page 2-13).*

Q: Is the engineer ok with the holes being as large as 11'-6" diameter on the 10' diameter foundation for the first 10 feet, then decreasing as the hole gets deeper to 10' diameter? (referring to situations where collapsing soil may occur)

*A: No. If collapsing occurs, temporary casing shall be used, or wet drilling (with the provision that approval is granted by the COR for the proposed wet drilling fluids).*

Q: If we encounter problems with collapsing soil while drilling the foundations can work 7 days a week, 10 hour days to make the schedule?

*A: It is up to the Contracting Officer's Representative's discretion.*

B. Attached is the Pre-bid Site Visit Sign-in Sheet.

C. The date and time set for receipt of proposals has not been extended from July 6, 2016.