

EST. GENERATION UPPER LIMIT (MW)	MO	Sep-20	Oct-20	Nov-20	Dec-20	Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Jan-22	
		MAX	1570	1553	1553	1570	1604	1638	1621	1604	1570	1536	1536	1553	1553	1553	1570	1621	1621
		MIN	1264	1154	1348	1363	1291	1104	1133	1121	1377	1536	1536	1553	1553	1413	917	1311	1304
EST. AVAILABLE CAPABILITY (MW)	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	
UNIT A0 ANNUAL UNIT INSPECTION		1	10																
UNIT A1 ANNUAL UNIT INSPECTION							1	26											
NERC/WEC TESTING							1	26											
Unexpected Outage																			
Unit A1 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A2 ANNUAL UNIT INSPECTION							1	26											
NERC/WEC TESTING							1	26											
Unexpected Outage																			
Unit A2 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A3 ANNUAL UNIT INSPECTION								29	31	1	30								
ROTOR LINK								29	31	1	30								
Unexpected Outage																			
Unit A3 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A4 ANNUAL UNIT INSPECTION								29	31	1	30								
ROTOR LINK								29	31	1	30								
Unexpected Outage																			
Unit A4 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A5 ANNUAL UNIT INSPECTION											1	28							
Unexpected Outage																			
Unit A5 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A6 ANNUAL UNIT INSPECTION/RAMP TEST											1	28							
Unexpected Outage																			
Unit A6 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A7 ANNUAL UNIT INSPECTION			19	31	1	13													
BACKIRON INSPECTION			19	31	1	7													
Unexpected Outage																			
Unit A7 Unavailable From -- To		0	0	19	31	1	13	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A8 ANNUAL UNIT INSPECTION			26	31	1	25													
CO2 SYSTEM NOZZLE MOD AND TESTING			26	31	1	25													
ISOPHASE BUSWORK			26	31	1	25													
Unexpected Outage																			
Unit A8 Unavailable From -- To		0	0	26	31	1	25	0	0	0	0	0	0	0	0	0	0	0	0
UNIT A9 ANNUAL UNIT INSPECTION/TURBINE INSP (2020 NOW FY21)			26	31	1	25													
OVERHAUL AND WICKET GATE															4	29			
ISOPHASE BUSWORK			26	31	1	25									4	31	1	30	
Unexpected Outage																			
Unit A9 Unavailable From -- To		0	0	26	31	1	25	0	0	0	0	0	0	0	4	31	1	30	0

The Max Capacity row above lists the most recent information on capacity provided to Western Area Power Administration in the unit capacity letter dated August 14, 2020. The 17-Month Operating Schedule incorporates calculated projections of future capacity based on the August 12th, 2020 24-Month Study and current Capacity letter.

EST. GENERATION UPPER LIMIT (MW)	MO MAX	Sep-20		Oct-20		Nov-20		Dec-20		Jan-21		Feb-21		Mar-21		Apr-21		May-21		Jun-21		Jul-21		Aug-21		Sep-21		Oct-21		Nov-21		Dec-21		Jan-22					
		MIN	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E	S	E					
EST. AVAILABLE CAPABILITY (MW)		1264	1154			1348	1363	1291	1104	1133	1121	1377	1536	1536	1553	1553	1413	1553	1553	1413	917	1311	1304																
UNIT N0 ANNUAL UNIT INSPECTION														8	26																								
UNIT N1 ANNUAL UNIT INSPECTION														1	31	1	2																						
WICKET GATE REPLACEMENT		1	30	1	31																																		
COOLING WATER RING REPLACEMENT														1	31	1	23																						
Unexpected Outage																																							
Unit N1 Unavailable From -- To		1	30	1	31	0	0	0	0	0	0	0	0	1	31	1	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
UNIT N2 ANNUAL UNIT INSPECTION														1	31	1	2																						
WICKET GATE PACKING														1	31	1	23																						
Unexpected Outage														1	31	1	23																						
Unit N2 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	1	31	1	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
UNIT N3 ANNUAL UNIT INSPECTION		28	30	1	23																																		
ROTOR REPAIR/REWEDGE																																							
NERC/WEC TESTING				13	23																																		
Unexpected Outage																																							
Unit N3 Unavailable From -- To		28	30	1	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
UNIT N4 ANNUAL UNIT INSPECTION		28	30	1	23																																		
NERC/WEC TESTING				12	23																																		
Unexpected Outage																																							
Unit N4 Unavailable From -- To		28	30	1	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
UNIT N5 ANNUAL UNIT INSPECTION														4	31	1	5																						
TRANSFORMER BUSHING REPLACEMENT														4	31	1	5																						
Unexpected Outage																																							
Unit N5 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	4	31	1	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
UNIT N6 ANNUAL UNIT INSPECTION														4	31	1	5																						
TRANSFORMER BUSHING REPLACEMENT														4	31	1	5																						
Unexpected Outage																																							
Unit N6 Unavailable From -- To		0	0	0	0	0	0	0	0	0	0	0	0	4	31	1	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
UNIT N7 ANNUAL UNIT INSPECTION																																							
TRANSFORMER BUSHING REPLACEMENT						30	30	1	31																														
BRAKE RING REPLACEMENT						30	30	1	31	1	31	1	28	1	31	1	30																						
Unexpected Outage																																							
Unit N7 Unavailable From -- To		0	0	0	0	30	30	1	31	1	31	1	28	1	31	1	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
UNIT N8 ANNUAL UNIT INSPECTION																																							
TRANSFORMER BUSHING REPLACEMENT						30	30	1	31																														
Unexpected Outage						30	30	1	31																														
Unit N8 Unavailable From -- To		0	0	0	0	30	30	1	31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

The Max Capacity row above lists the most recent information on capacity provided to Western Area Power Administration in the unit capacity letter dated August 14th, 2020. The 17-Month Operating Schedule incorporates calculated projections of future capacity based on the August 12th, 2020 24-Month Study and current Capacity letter.