

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line  
Vegetation Management Task Order No. 110 (Hand Work Only)  
Montrose and Delta Counties, Colorado  
Project No. 2016-035**

- A. Brief Description of Proposal:** Western Area Power Administration (WAPA) proposes to conduct routine survey inspections and vegetation management along the Curecanti - North Fork (CCI-NFK) 230-kV Transmission Line in Delta and Montrose Counties, Colorado. Routine vegetation management will be conducted through tree removal and brush clearing within the right-of-way (ROW) between the Curecanti (CCI) Substation and the North Fork (NFK) Substation. Trained crews will inventory the vegetation in the ROW, measure electrical clearance distances between the conductor and vegetation, and cut down any trees that meet or exceed the allowable clearance distance. Any "danger" trees, as defined by WAPA Order 430.1B and vegetation that constitutes an electrical hazard to the lines will be removed. Electrical safety and reliability standards require that this vegetation be removed to avoid hazardous situations and disruption of electrical service. Also proposed is routine maintenance to clear vegetation in and around transmission line structures, as needed, to ensure access to the structures. Vegetation that is 50-feet or less from transmission line structures may be managed, as necessary.

The proposed work and travel will be confined to WAPA's existing ROW and access roads. Equipment used will include rubber-tired vehicles, chainsaws, and other hand tools. Access to and along the transmission line ROW shall be gained by foot, ATV, or by pickup truck carrying workers, equipment, or towable equipment such as chippers or shredders. Advancement along the ROW will be made by driving on the access road to the appropriate site, then allowing the crews with hand tools to hike along the ROW, cutting targeted vegetation. Only unwanted or target vegetation will be removed. Non-target vegetation will not be disturbed. During the project, actions shall be taken to preserve the maximum amount of low-growing native species. No mechanical tree removal is authorized as part of this environmental review.

- B. Number and Title of the Categorical Exclusion Being Applied:** (See text in 10 CFR Part 1021, Subpart D.)

**B1.3. Routine Maintenance:**

**Routine maintenance activities and custodial services for buildings, structures, rights-of-way, infrastructures (including, but not limited to, pathways, roads, and railroads), vehicles and equipment, and localized vegetation and pest control**, during which operations may be suspended and resumed, provided that the activities would be conducted in a manner in accordance with applicable requirements. Custodial services are activities to preserve facility appearance, working conditions, and sanitation (such as cleaning, window washing, lawn mowing, trash collection, painting, and snow removal). Routine maintenance activities, corrective (that is, repair), preventive, and predictive, are required to maintain and preserve buildings, structures, infrastructures, and equipment in a condition suitable for a facility to be used for its designated purpose. Such maintenance may occur as a result of severe weather (such as hurricanes, floods, and tornados), wildfires, and other such events. Routine maintenance may result in replacement to the extent that replacement is in-kind and is not a substantial upgrade or improvement. In-kind replacement includes installation of new components to replace outmoded components, provided that the replacement does not result in a significant change in the expected useful life, design capacity, or function of the facility. Routine maintenance does not include replacement of a major component

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line  
Vegetation Management Task Order No. 110 (Hand Work Only)  
Montrose and Delta Counties, Colorado  
Project No. 2016-035**

that significantly extends the originally intended useful life of a facility (for example, it does not include the replacement of a reactor vessel near the end of its useful life). Routine maintenance activities include, but are not limited to:

- (a) Repair or replacement of facility equipment, such as lathes, mills, pumps, and presses;
- (b) Door and window repair or replacement;
- (c) Wall, ceiling, or floor repair or replacement;
- (d) Reroofing;
- (e) Plumbing, electrical utility, lighting, and telephone service repair or replacement;
- (f) Routine replacement of high-efficiency particulate air filters;
- (g) Inspection and/or treatment of currently installed utility poles;
- (h) Repair of road embankments;
- (i) Repair or replacement of fire protection sprinkler systems;
- (j) Road and parking area resurfacing, including construction of temporary access to facilitate resurfacing, and scraping and grading of unpaved surfaces;
- (k) Erosion control and soil stabilization measures (such as reseeded, gabions, grading, and revegetation);
- (l) Surveillance and maintenance of surplus facilities in accordance with DOE Order 435.1, "Radioactive Waste Management," or its successor;
- (m) Repair and maintenance of transmission facilities, such as replacement of conductors of the same nominal voltage, poles, circuit breakers, transformers, capacitors, crossarms, insulators, and downed powerlines, in accordance, where appropriate, with 40 CFR part 761 ("Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions") or its successor;
- (n) Routine testing and calibration of facility components, subsystems, or portable equipment (such as control valves, in-core monitoring devices, transformers, capacitors, monitoring wells, lysimeters, weather stations, and flumes);
- (o) Routine decontamination of the surfaces of equipment, rooms, hot cells, or other interior surfaces of buildings (by such activities as wiping with rags, using strippable latex, and minor vacuuming), removal of contaminated intact equipment and other materials (not including spent nuclear fuel or special nuclear material in nuclear reactors); and
- (p) **Removal of debris.**

**C. Regulatory Requirements in 10 CFR 1021.410 (b):** (See full text in regulation and attached checklist.)

- 1) The proposed action fits within a class of actions listed in Appendix A or B to Subpart D.

For classes of actions listed in Appendix B, the following conditions are integral elements. To fit within a class, the proposal must not:

- Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders;

# ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

## Rocky Mountain Region, Western Area Power Administration

### Curecanti - North Fork 230-kV Transmission Line Vegetation Management Task Order No. 110 (Hand Work Only) Montrose and Delta Counties, Colorado *Project No. 2016-035*

- Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;
  - Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;
  - Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, State, or local government, or a federally recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to, those listed in paragraph B. (4) (see Attachment A).
- 2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal.
- 3) The proposal is not “connected” to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

#### **D. Special Stipulations Pertaining to the Proposal:**

If the scope of work of this project changes, WAPA’s Environmental Division must be contacted to determine whether additional environmental review is required.

**This Categorical Exclusion expires March 1, 2017.** If all project work has not been completed by the expiration date, or if the need for an environmental compliance extension is anticipated, WAPA’s Environmental Division must be contacted for an updated environmental review.

The proposed action shall be completed on foot with hand tools (i.e. chainsaws), with no brush piling or dragging of felled trees through known cultural resource site boundaries. All vehicular traffic (other than with an ATV) will be confined to existing access roads.

**To limit impacts to Gunnison sage-grouse critical habitat, the following stipulations shall be followed:**

- **If possible, trim rather than remove the entire tree.**
- **If the entire tree must be removed, dragging of vegetation shall be avoided.**
- **Any felled trees shall be cut and stacked in orderly piles as close as possible to where the tree was felled.**

## ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

**Curecanti - North Fork 230-kV Transmission Line**  
**Vegetation Management Task Order No. 110 (Hand Work Only)**  
**Montrose and Delta Counties, Colorado**  
*Project No. 2016-035*

- **Avoid felling of trees onto shrubs, especially sagebrush.**
- **The vegetation management crews shall provide WAPA with pre- and post-treatment photographs of the treated vegetation and the surrounding work area.**

If any cultural resources are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area shall halt immediately, WAPA's archaeologist shall be contacted immediately, and the resource shall be evaluated by an archaeologist or historian who meets the Secretary of the Interior's Professional Qualification Standards (36 CFR Part 61). Work in the area of discovery shall not resume until notification to proceed is provided by WAPA's archaeologist.

If any possible human remains are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area shall halt immediately and WAPA's archaeologist shall be notified immediately by telephone (no later than 24 hours from the time of discovery). A reasonable effort shall be made to protect the remains from looting and/or further damage. If the discovery is located on Federal or Tribal lands, the provisions of the Native American Graves Protection and Repatriation Act of 1990 (as amended) and implementing regulations 43 CFR 10 shall be followed. In this situation, a mandatory minimum 30 day halt to work activities in the area of discovery is required. If the discovery is located on State or private lands, the appropriate State laws regarding the discovery of human remains shall be followed. Work in the area of discovery shall not resume until notification to proceed is provided by WAPA's archaeologist.

WAPA has a clean vehicle policy intended to prevent the transport of non-native and invasive plants and animals, including noxious weeds and aquatic nuisance species. Operators will be required to thoroughly wash all vehicles and equipment (trailers, trucks, UTVs, etc.) before entering the action area and working on the project.

WAPA shall exercise care to preserve the natural landscape and shall conduct this project to prevent any unnecessary destruction, scarring, or defacing of the natural surroundings in the project vicinity. Except where clearing is required, vegetation shall be preserved and shall be protected from damage by WAPA's operations and equipment. If operations or equipment cause terrain damage, the maintenance crew shall repair the damage.

To minimize impacts to the environment and prevent damage to access roads, operation of off-road equipment will not be permitted during periods of heavy rains, when soils are wet, or when excessive soil damage may occur due to unsuitable operating conditions. Project work shall not be conducted during periods when the soil is too wet to adequately support equipment. If equipment creates ruts in excess of six inches deep, the soil shall be deemed too wet to adequately support the equipment.

To comply with Section 404 of the Clean Water Act and Executive Order 11990, Protection of Wetlands, any work adjacent to or in a wetland will be accomplished by hand. No mechanized

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**


**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line  
Vegetation Management Task Order No. 110 (Hand Work Only)  
Montrose and Delta Counties, Colorado  
*Project No. 2016-035***

equipment other than hand carried chain saws may be used below the ordinary high water mark in wetland areas.

To prevent spills of fuel, oil, hydraulic fluid, or other petroleum products into the environment during fueling or maintenance activities for vehicles, equipment, or tools, project site personnel shall maintain an appropriately sized containment device to contain incidental spills under any work area. All fueling activities shall take place over a drip pan lined with absorbent pads. Used absorbent pads shall be placed into an approved DOT container and removed from the project site for appropriate disposal. In addition, project site personnel shall have on hand sufficient supplies, such as absorbent mats, booms, socks, or other spill containment materials, to be available for immediate spill prevention, containment, and cleanup prior to commencing any refueling activities.

- E. Determination:** Based on my review of information provided to me and in my possession concerning the proposed action, I have determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is categorically excluded from requirements for an EA or an EIS.

  
\_\_\_\_\_  
Signature

Date: 21 Nov 2016

Brian Little  
Environmental Manager  
Rocky Mountain Customer Service Region  
Western Area Power Administration

Prepared by: Brian Little

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line  
Vegetation Management Task Order No. 110 (Hand Work Only)**

**Montrose and Delta Counties, Colorado**

**Project No. 2016-035**

**ATTACHMENT A**

**Conditions That Are Integral Elements of the Classes  
of Actions in Appendix B That Apply to This Proposal**

Checklist for Categorical Exclusion Determination, revised Nov. 2011

<b>Application of Categorical Exclusions (1021.410)</b>	<b>Disagree</b>	<b>Agree</b>	<b>Unknown</b>
(b)(1) The proposal fits within a class of actions that is listed in appendix B to subpart D.		X	
(b)(2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal, including, but not limited to, scientific controversy about the environmental effects of the proposal; uncertain effects or effects involving unique or unknown risks; and unresolved conflicts concerning alternate uses of available resources.		X	
(b)(3) The proposal has not been segmented to meet the definition of a categorical exclusion. Segmentation can occur when a proposal is broken down into small parts in order to avoid the appearance of significance of the total action. The scope of a proposal must include the consideration of connected and cumulative actions, that is, the proposal is not connected to other actions with potentially significant impacts (40 CFR 1508.25(a)(1)), is not related to other actions with individually insignificant but cumulatively significant impacts (40 CFR 1508.27(b)(7)), and is not precluded by 40 CFR 1506.1 or § 1021.211 of this part concerning limitations on actions during EIS preparation.		X	
<b>B. Conditions that are Integral Elements of the Classes of Actions in Appendix B.</b>	NO	YES	Unknown
(1) Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety and health, or similar requirements of DOE or Executive Orders.	X		
(2) Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities.	X		
(3) Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases.	X		
(4) Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, state, or local government, or a federally recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line  
Vegetation Management Task Order No. 110 (Hand Work Only)**

**Montrose and Delta Counties, Colorado**

***Project No. 2016-035***

present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to:			
(i) Property (such as sites, buildings, structures, and objects) of historic, archaeological, or architectural significance designated by a Federal, state, or local government, or property determined to be eligible for listing on the National Register of Historic Places;	X		
(ii) Federally-listed threatened or endangered species or their habitat (including critical habitat) or Federally- proposed or candidate species or their habitat (Endangered Species Act); state-listed or state-proposed endangered or threatened species or their habitat; Federally-protected marine mammals and Essential Fish Habitat (Marine Mammal Protection Act; Magnuson-Stevens Fishery Conservation and Management Act); and otherwise Federally-protected species (such as under the Bald and Golden Eagle Protection Act or the Migratory Bird Treaty Act);	X		
(iii) Floodplains and wetlands (as defined in 10 CFR 1022.4, —Compliance with Floodplain and Wetland Environmental Review Requirements: “Definitions,” or its successor);	X		
(iv) Areas having a special designation such as Federally- and state-designated wilderness areas, national parks, national monuments, national natural landmarks, wild and scenic rivers, state and Federal wildlife refuges, scenic areas (such as National Scenic and Historic Trails or National Scenic Areas), and marine sanctuaries;	X		
(v) Prime or unique farmland, or other farmland of statewide or local importance, as defined at 7 CFR 658.2(a), —Farmland Protection Policy Act: Definitions, or its successor;	X		
(vi) Special sources of water (such as sole-source aquifers, wellhead protection areas, and other water sources that are vital in a region); and	X		
(vii) Tundra, coral reefs, or rain forests; or	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**  
**Rocky Mountain Region, Western Area Power Administration**

**Curecanti - North Fork 230-kV Transmission Line**  
**Vegetation Management Task Order No. 110 (Hand Work Only)**  
**Montrose and Delta Counties, Colorado**  
*Project No. 2016-035*

(5) Involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.	X		
---	---	--	--