

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION
Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line
New Point of Delivery
Weld County, Colorado
Project Number: 2017-069

A. Brief Description of Proposal: Western Area Power Administration (WAPA), Rocky Mountain Region (RMR), proposes to approve a new Point of Delivery (POD) interconnection by Tri-State Generation and Transmission Association, Inc. (Tri-State) to WAPA's Terry Street-Erie (TRR-EE) 115-kV Transmission Line located in Weld County, Colorado. Tri-State proposes to install a new substation (Lazy Dog) adjacent to WAPA's right-of-way (ROW). A portion of this substations footprint will be located on WAPA's ROW. Tri-State would connect the new Lazy Dog Substation to WAPA's service via a new tap (Lazy Dog Tap) that would be constructed northeast of TRR-EE, with transmission line alignment and structure modifications occurring within WAPA's existing and new ROWs between existing TRR-EE Structures 29/6 and 29/8 and the Lazy Dog Substation. Existing TRR-EE Structure 29/7 would be removed and replaced with two new structures to be numbered 29/7A and 29/7B. To accommodate this construction, a shoo-fly pole also would be temporarily installed between existing Structures 29/7A and 29/7B. WAPA will conduct the structure relocations and Tri-State will conduct all other construction activities.

B. Number and Title of the Categorical Exclusion Being Applied: (See text in 10 CFR Part 1021, Subpart D.)

B4.11 Electric power substations and interconnection facilities

C. Regulatory Requirements in 10 CFR Part 1021.410 (b): (See full text in regulation and attached checklist.)

(1) The proposed action fits within a class of actions listed in Appendix A or B to Subpart D.

For classes of actions listed in Appendix B, the following conditions are integral elements. To fit within a class, the proposal must not:

- Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders;
- Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;
- Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line

New Point of Delivery

Weld County, Colorado

Project Number: 2017-069

- Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, State, or local government, or a federally-recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to, those listed in paragraph B. (4) (see Attachment A).
- (2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal.
- (3) The proposal is not “connected” to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR Part 1506.1 or 10 CFR Part 1021.211.

D. Special Stipulations Pertaining to the Proposal:

- 1) If the scope of work of this project changes, RMR’s Environment Department must be contacted to determine whether additional environmental review is required.
- 2) **This Categorical Exclusion expires three years from signature date.** If all project work has not been completed by the expiration date, or if the need for an environmental compliance extension is anticipated, RMR’s Environment Department must be contacted for an updated environmental review.
- 3) Transmission line and substation components must be designed and constructed in conformance with the most current editions of *Suggested Practices for Avian Protection on Power Lines* and *Reducing Avian Collisions with Power Lines*, both published by the Avian Power Line Interaction Committee (APLIC) to minimize avian collision and electrocution risk while maintaining safe and reliable electrical service.
- 4) If any cultural resources are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area shall halt immediately, RMR’s Archaeologist shall be contacted immediately. Work in the area of discovery shall not resume until notification to proceed is provided by RMR’s Archaeologist.

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line

New Point of Delivery

Weld County, Colorado

Project Number: 2017-069

- 5) If any possible human remains are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area shall halt immediately and RMR's Archaeologist shall be notified immediately by telephone (no later than 24 hours from the time of discovery). A reasonable effort shall be made to protect the remains from looting and/or further damage. Work in the area of discovery shall not resume until notification to proceed is provided by RMR's Archaeologist.
 - 6) To prevent the transport of non-native and invasive plants and animals, including noxious weeds and aquatic nuisance species, work crews must thoroughly wash all vehicles and equipment (trailers, trucks, UTVs, etc.) before entering the action area and working on the project.
 - 7) Activities involving the use of fuel, oil, hydraulic fluid, or other petroleum products must comply with RMR's Spill Response Plan (SRP).
- E. **Determination**: Based on my review of information provided to me and in my possession concerning the proposed action, I have determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is categorically excluded from requirements for an EA or an EIS.

Signature and Date

Brian Little
NEPA Compliance Officer
Rocky Mountain Customer Service Region
Western Area Power Administration

Prepared by: Erik Bray

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line

New Point of Delivery

Weld County, Colorado

Project Number: 2017-069

ATTACHMENT A

**Conditions That Are Integral Elements of the Classes
of Actions in Appendix B That Apply to This Proposal**

Checklist for Categorical Exclusion Determination, revised Nov. 2011

Application of Categorical Exclusions (1021.410)	Disagree	Agree	Unknown
(b)(1) The proposal fits within a class of actions that is listed in appendix B to subpart D.		X	
(b)(2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal, including, but not limited to, scientific controversy about the environmental effects of the proposal; uncertain effects or effects involving unique or unknown risks; and unresolved conflicts concerning alternate uses of available resources.		X	
(b)(3) The proposal has not been segmented to meet the definition of a categorical exclusion. Segmentation can occur when a proposal is broken down into small parts in order to avoid the appearance of significance of the total action. The scope of a proposal must include the consideration of connected and cumulative actions, that is, the proposal is not connected to other actions with potentially significant impacts (40 CFR Part 1508.25(a)(1)), is not related to other actions with individually insignificant but cumulatively significant impacts (40 CFR Part 1508.27(b)(7)), and is not precluded by 40 CFR Part 1506.1 or § 1021.211 of this part concerning limitations on actions during EIS preparation.		X	
B. Conditions that are Integral Elements of the Classes of Actions in Appendix B.	NO	YES	Unknown
(1) Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety and health, or similar requirements of DOE or Executive Orders.	X		
(2) Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities.	X		
(3) Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases.	X		
(4) Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or	X		

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line

New Point of Delivery

Weld County, Colorado

Project Number: 2017-069

regulation by Federal, State, or local government, or a federally-recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to:			
(i) Property (such as sites, buildings, structures, and objects) of historic, archaeological, or architectural significance designated by a Federal, State, or local government, or property determined to be eligible for listing on the National Register of Historic Places;	X		
(ii) Federally-listed threatened or endangered species or their habitat (including critical habitat) or Federally-proposed or candidate species or their habitat (Endangered Species Act); state-listed or state-proposed endangered or threatened species or their habitat; Federally-protected marine mammals and Essential Fish Habitat (Marine Mammal Protection Act; Magnuson-Stevens Fishery Conservation and Management Act); and otherwise Federally-protected species (such as under the Bald and Golden Eagle Protection Act or the Migratory Bird Treaty Act);	X		
(iii) Floodplains and wetlands (as defined in 10 CFR Part 1022.4, —Compliance with Floodplain and Wetland Environmental Review Requirements: “Definitions,” or its successor);	X		
(iv) Areas having a special designation such as Federally-and State-designated wilderness areas, national parks, national monuments, national natural landmarks, wild and scenic rivers, state and Federal wildlife refuges, scenic areas (such as National Scenic and Historic Trails or National Scenic Areas), and marine sanctuaries;	X		
(v) Prime or unique farmland, or other farmland of statewide or local importance, as defined at 7 CFR Part 658.2(a), —Farmland Protection Policy Act: Definitions, or its successor;	X		
(vi) Special sources of water (such as sole-source aquifers, wellhead protection areas, and other water sources that are vital in a region); and	X		
(vii) Tundra, coral reefs, or rain forests; or	X		

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Terry Street - Erie 115-kV Transmission Line

New Point of Delivery

Weld County, Colorado

Project Number: 2017-069

<p>(5) Involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.</p>	<p>X</p>		
--	----------	--	--