

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**  
**Rocky Mountain Region, Western Area Power Administration**

**Midway Substation Improvements**  
**El Paso County, CO**  
***Project Number: 2018-099***  
***Expiration Date: December 31, 2021***

**A. Brief Description of Proposal:** Western Area Power Administration (WAPA), Rocky Mountain Region (RMR), proposes to construct various improvements at its Midway Substation (MID) in El Paso County, Colorado. Transformer bank KV1A (units 1-3) and a spare (unit 4) 100 MVA 230/115 kV transformer would be removed from the site and replaced with a single tank 200 MVA KV1A 230/115 kV transformer in the same general location. One 230 kV and one 115 kV circuit breakers would be added. Two disconnect switches would be added, and all existing switches would be replaced in bays V1 and Y1. Also, two open-frame air-core 13.8 kV line reactor banks (KW1A and KW2A), and their associated equipment, located adjacent to the KV1A bank, would be removed. Some associated sections of rigid bus, bus supports, and foundations would also be removed from the 230/115/13.8 kV buswork. The existing transformer's panel board components would be removed and new panel board components would be installed inside the MID control building. All work would occur within the MID fenced perimeter and control building and existing access roads would be used.

**B. Number and Title of the Categorical Exclusion Being Applied:** (See text in 10 CFR Part 1021, Subpart D.)

B4.11 Electric power substations and interconnection facilities

**C. Regulatory Requirements in 10 CFR Part 1021.410 (b):** (See full text in regulation and attached checklist.)

1) The proposed action fits within a class of actions listed in Appendix A or B to Subpart D.

For classes of actions listed in Appendix B, the following conditions are integral elements. To fit within a class, the proposal must not:

- Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders;
- Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;
- Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;

# **ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

## **Rocky Mountain Region, Western Area Power Administration**

### **Midway Substation Improvements**

**El Paso County, CO**

***Project Number: 2018-099***

***Expiration Date: December 31, 2021***

- Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, State, or local government, or a federally-recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to, those listed in paragraph B. (4) (see Attachment A).
- 2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal.
  - 3) The proposal is not “connected” to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

#### **D. Special Stipulations Pertaining to the Proposal:**

- 1) If the scope of work of this project changes, WAPA’s Environment Department must be contacted to determine whether additional environmental review is required.
- 2) This Categorical Exclusion **expires December 31, 2021**. If all project work has not been completed by the expiration date, or if the need for an environmental compliance extension is anticipated, RMR’s Environment Department must be contacted for an updated environmental review.
- 3) Any injured or dead birds encountered on WAPA’s right-of-way (ROW) must be immediately reported to the RMR Avian Protection Leads by telephone at 970-593-8803 or 970-278-7119. Additional documentation, such as photographs and GPS coordinates, may be requested to support RMR’s reporting requirements to the U.S. Fish and Wildlife Service.
- 4) Transmission line and substation components must be designed and constructed in conformance with the most current editions of Suggested Practices for Avian Protection on Power Lines and Reducing Avian Collisions with Power Lines, both published by the Avian Power Line Interaction Committee (APLIC) to minimize avian collision and electrocution risk while maintaining safe and reliable electrical service.
- 5) If any cultural resources are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area must halt immediately, RMR’s Archaeologist must be contacted immediately. Work in the area of discovery must not resume until notification to proceed is provided by RMR’s Archaeologist.

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**  
**Rocky Mountain Region, Western Area Power Administration**

**Midway Substation Improvements**  
**El Paso County, CO**  
***Project Number: 2018-099***  
***Expiration Date: December 31, 2021***

- 6) If any possible human remains are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area must halt immediately and RMR's Archaeologist must be notified immediately by telephone (no later than 24 hours from the time of discovery). A reasonable effort must be made to protect the remains from looting and/or further damage. Work in the area of discovery must not resume until notification to proceed is provided by RMR's Archaeologist.
- 7) To prevent the transport of non-native and invasive plants and animals, including noxious weeds and aquatic nuisance species, work crews must thoroughly wash all vehicles and equipment (trailers, trucks, UTVs, etc.) before entering the action area and working on the project.
- 8) Installation of equipment in substations must conform to WAPA's requirements and must be approved by WAPA. Oil-filled equipment, including bushings, must not contain polychlorinated biphenyls (PCB). In addition, oil-filled equipment must be permanently labeled by the manufacturer as non-PCB. Certification must be provided to WAPA at or before the time of installation. Oil-filled equipment may require an oil spill containment system to comply with Federal or state regulations.
- 9) Activities involving the use of fuel, oil, hydraulic fluid, or other petroleum products must comply with RMR's Spill Response Plan (SRP).

**E. Determination:** Based on my review of information provided to me and in my possession concerning the proposed action, I have determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is categorically excluded from requirements for an EA or an EIS.

---

Signature and Date

Brian Little  
NEPA Compliance Officer  
Rocky Mountain Customer Service Region  
Western Area Power Administration

Prepared by: Tim Snowden, NEPA Planner

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Midway Substation Improvements**

**El Paso County, CO**

***Project Number: 2018-099***

***Expiration Date: December 31, 2021***

**ATTACHMENT A**

**Conditions That Are Integral Elements of the Classes  
of Actions in Appendix B That Apply to This Proposal**

Checklist for Categorical Exclusion Determination, revised Nov. 2011

<b>Application of Categorical Exclusions (1021.410)</b>	<b>Disagree</b>	<b>Agree</b>	<b>Unknown</b>
(b)(1) The proposal fits within a class of actions that is listed in appendix B to subpart D.		X	
(b)(2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal, including, but not limited to, scientific controversy about the environmental effects of the proposal; uncertain effects or effects involving unique or unknown risks; and unresolved conflicts concerning alternate uses of available resources.		X	
(b)(3) The proposal has not been segmented to meet the definition of a categorical exclusion. Segmentation can occur when a proposal is broken down into small parts in order to avoid the appearance of significance of the total action. The scope of a proposal must include the consideration of connected and cumulative actions, that is, the proposal is not connected to other actions with potentially significant impacts (40 CFR 1508.25(a)(1)), is not related to other actions with individually insignificant but cumulatively significant impacts (40 CFR 1508.27(b)(7)), and is not precluded by 40 CFR 1506.1 or § 1021.211 of this part concerning limitations on actions during EIS preparation.		X	
<b>B. Conditions that are Integral Elements of the Classes of Actions in Appendix B.</b>	<b>NO</b>	<b>YES</b>	<b>Unknown</b>
(1) Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety and health, or similar requirements of DOE or Executive Orders.	X		
(2) Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;	X		
(3) Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;	X		
(4) Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, state, or local government, or a federally recognized Indian tribe. An	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Midway Substation Improvements  
El Paso County, CO  
Project Number: 2018-099  
Expiration Date: December 31, 2021**

action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to:			
(i) Property (such as sites, buildings, structures, and objects) of historic, archaeological, or architectural significance designated by a Federal, state, or local government, or property determined to be eligible for listing on the National Register of Historic Places;	X		
(ii) Federally-listed threatened or endangered species or their habitat (including critical habitat) or Federally- proposed or candidate species or their habitat (Endangered Species Act); state-listed or state-proposed endangered or threatened species or their habitat; Federally-protected marine mammals and Essential Fish Habitat (Marine Mammal Protection Act; Magnuson-Stevens Fishery Conservation and Management Act); and otherwise Federally-protected species (such as under the Bald and Golden Eagle Protection Act or the Migratory Bird Treaty Act);	X		
(iii) Floodplains and wetlands (as defined in 10 CFR 1022.4, —Compliance with Floodplain and Wetland Environmental Review Requirements: “Definitions,” or its successor);	X		
(iv) Areas having a special designation such as Federally- and state-designated wilderness areas, national parks, national monuments, national natural landmarks, wild and scenic rivers, state and Federal wildlife refuges, scenic areas (such as National Scenic and Historic Trails or National Scenic Areas), and marine sanctuaries;	X		
(v) Prime or unique farmland, or other farmland of statewide or local importance, as defined at 7 CFR 658.2(a), —Farmland Protection Policy Act: Definitions, or its successor;	X		
(vi) Special sources of water (such as sole-source aquifers, wellhead protection areas, and other water sources that are vital in a region); and	X		
(vii) Tundra, coral reefs, or rain forests; or	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Midway Substation Improvements**  
**El Paso County, CO**  
*Project Number: 2018-099*  
*Expiration Date: December 31, 2021*

(5) Involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.	X		
---	---	--	--